WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48443
Permit No.
Basin 162
NOTICE OF INTENT NO. 17032

1. OWNER George Cantero
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1220 Dollar St

2. LOCATION SW ¼ SW ¼ Sec. 11 T. 21 N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-361-13 (Parcel No.) Thousandaire Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	13	8
Calichie		13	16	3
Clay		16	27	11
Calichie		27	30	3
Clay		30	41	11
Calichie		41	44	3
Clay		44	53	9
Calichie		53	58	5
Clay		58	69	11
Calichie	WB	69	73	4
Clay		73	86	13
Calichie	WB	86	89	3
Clay		89	118	29
Calichie	WB	118	121	3
~~[illegible]~~		~~121~~		
Clay		121	125	4
Limestone	WB	125	132	7
Clay		132	135	3
Calichie	WB	135	138	3
Clay		138	140	2

RECEIVED
SEP 1 _ 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 21, 19 95
Date completed July 23, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From ___ feet to ___ feet
From 100 feet to 120 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 8-24-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627