

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **27288**

1. OWNER **Conti Construction** ADDRESS AT WELL LOCATION **Desert Rose Golf Course**  
MAILING ADDRESS **20 20204 NV 89118**

2. LOCATION  $\frac{1}{4}$  N  $\frac{1}{2}$  E  $\frac{1}{4}$  Sec. **9** T. **21 S** R. **60 E** **Clark** County  
PERMIT NO. **061235** Issued by Water Resources Parcel No. **240-260-008** Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other **Temp**

4. PROPOSED USE **dewater**  
 Domestic  Irrigation  Test  Monitor  Stock  Municipal/Industrial

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other **Auger**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>Dirt &amp; Sand</b>		<b>0</b>	<b>5</b>	<b>5</b>
<b>Swampy Clay</b>		<b>5</b>	<b>20</b>	<b>15</b>
<b>Fine Sand</b>		<b>20</b>	<b>28</b>	<b>8</b>
<b>Sandy Clay</b>		<b>28</b>	<b>32</b>	<b>4</b>
<b>Clay w/ Caliche</b>		<b>32</b>	<b>33</b>	<b>1</b>
<b>Clay w/ Sand</b>		<b>33</b>	<b>40</b>	<b>7</b>

8. WELL CONSTRUCTION  
Depth Drilled **40** Feet Depth Cased **40** Feet

HOLE DIAMETER (BIT SIZE)  
From **24** Inches To **40** Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8</b>		<b>3/4</b>	<b>0</b>	<b>40</b>

Perforations:  
Type perforation **Slot**  
Size perforation **20 22 30 40**  
From **20** feet to **40** feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No **40**  
From **0** feet to **40** feet

9. WATER LEVEL  
Static water level **20** feet below land surface  
Artesian flow **None** G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature **60.1** °F Quality **Good**

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **William Contract Dewatering**  
Address **536 E Mainland Ontario CA 91761**  
Nevada contractor's license number issued by the State Contractor's Board **31246**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M 1968**  
Signed **[Signature]**  
Date **6-17-95**

Date started **6-17**, 19**95**  
Date completed **6-17**, 19**95**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Fect Below Static)	Time (Hours)

