




WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 48458
 Permit No. 203
 Basin 203



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 14120

1. OWNER Gary Nelson ADDRESS AT WELL LOCATION Mile Marker #106 U.S. 93 Caliente Nev.
 MAILING ADDRESS 8021 Fire Horn Las Vegas, Nev. 89123

2. LOCATION S 1/4 E 1/4 Sec 3 T. 3 N. R. 67 E. Lincoln Highland Knolls County
 PERMIT NO. 203 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders - sand		0	5.3	5.3
Clay - boulders		5.3	175	172
gravel - clay	X	175	210	35
clay		210	220	10
TD 220'				

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>2</u>	<u>1/8</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation factory
 Size perforation 1 1/2" x 3"
 From 150' feet to 220' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature cold °F Quality good

Date started 6-6-95, 19____
 Date completed 6-11-95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>28</u>	<u>2</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling Contractor
 Address P.O. Box 54 Hiko Nev. 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191

Signed Mike O. Davis
 By driller performing actual drilling on site or contractor
 Date 6-12-95

