

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24714

1. OWNER TEXACO SERVICE STATION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1457 S. CARSON ST. CARSON CITY, NV. SAME  
 2. LOCATION NW 1/4 NW 1/4 Sec. 20 T 15 N 20 E CARSON County  
 PERMIT NO. M/D-324C 4-011-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other AUGER

6. LITHOLOGIC LOG SP-5

Material	Water Strata	From	To	Thickness
<u>ASPHALTIC CONCRETE</u>	<u>-</u>	<u>0</u>	<u>4"</u>	<u>4"</u>
<u>BROWN GRAVEL</u>	<u>-</u>	<u>4"</u>	<u>1'</u>	<u>8"</u>
<u>BLACK-GRAY SANDY SILTY CLAY</u>	<u>5'</u>	<u>1'</u>	<u>5'</u>	<u>4'</u>
<u>GRAY SILTY CLAY</u>		<u>5'</u>	<u>8'</u>	<u>3'</u>
<u>BROWN SANDY SILTY CLAY</u>		<u>8'</u>	<u>12'</u>	<u>4'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 12 Feet Depth Cased 12 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 12 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>SCH. 40</u>	<u>PVC</u>	<u>0</u>	<u>12</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.020"  
 From 6 1/2 feet to 12 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 6 1/2  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 6 1/2 feet to 12 feet

Date started 3/28 1994  
 Date completed 3/28 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDRESEN EXPLORATION DRILLING  
 Address 1635 BELFORD RD.  
RENO, NV. 89509  
 Nevada contractor's license number 0034525  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1028  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 6/3/94