WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 48488
Permit No.
Basin 007

NOTICE OF INTENT NO. 37443

1. OWNER RIVER CITY PETROLEUM
MAILING ADDRESS 8650 SO. VIRGINIA ST. RENO, NEV
ADDRESS AT WELL LOCATION SAME

2. LOCATION A ¼ A ¼ Sec. 6 T. 18 N/S R. 20 E. WASHOE County
PERMIT NO. MW/C 898 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LIGHT GRAVELS-NI-	9.5	0	15'	15'
LIGHT SANDS				

8. WELL CONSTRUCTION
Depth Drilled 15' Feet Depth Cased 15' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0	Feet	15'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	PVC	0	15

Perforations:
Type perforation FAC.
Size perforation .020
From 5' feet to 15' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15' feet to 3' feet

9. WATER LEVEL
Static water level 9.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andreson Drilling (Contractor)
Address 1635 BALFORD RD. (Contractor)
RENO NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2/11/95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

Date started 2-7, 19 95
Date completed 2-7, 19 95

'95 MAY -5 A11:09 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627