

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28920

1. OWNER LEHMAN + SONS BUILDERS ADDRESS AT WELL LOCATION 991 EARLIER CT GARDNERVILLE  
 MAILING ADDRESS FISH SPRINGS, NV

2. LOCATION SE 1/4 SE 1/4 Sec. 13 T. 12 N/S R. 20 E. DOUGLAS County  
 PERMIT NO. 29-442-22 Parcel No. \_\_\_\_\_ Subdivision Name RUBENSTROTH  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY/GRAVEL		0	94	94
SAND/GRAVEL		94	141	47
SANDY CLAY		141	149	8
Cemented GRAVEL		149	202	53
SAND/GRAVEL	✓	202	255	53
Cemented/GRAVEL		255	260	5

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>50</u> Feet	<u>50</u> Feet
<u>9 7/8</u> Inches	<u>50</u> Feet	<u>260</u> Feet	<u>260</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations:  
 Type perforation FACTORY SUBMITTED  
 Size perforation 3 X 3 / 32  
 From 240 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 137 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997  
 Signed David J. Reisel  
 By driller performing actual drilling on site or contractor  
 Date 10-12-95

Date started 10/4 1995  
 Date completed 10/10 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25</u>	<u>-</u>	<u>4</u>

RECEIVED  
 95 NOV 13 AM 11:57  
 STATE ENGINEERS OFFICE