

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Log No. **48504**
 Permit No. _____
 Basin. **0871**
 Page 1 of 2 pages
 NOTICE OF INTENT NO. 22856

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Broadbent & Associates, Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1000 Bible Way, Suite 57 Allied Petroleum
Reno, Nevada 89502 2500 E. 4th St., Reno, Nv.
 2. LOCATION 1/4 087 1/4 Sec. 7 T. 19N N/S R. 20 E Washoe County
 PERMIT NO. M/O 702-A SP-5 008-228-01 E Reno Area
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravelly silt: Silty gravels, gravel-sand-silt mixtures.		0	2	2
Clay: Inorganic clays of low to midium plasticity, gravelly clays, sandy clays, silty clays, lean clays.		2	4	2
Gravelly sand: Poorly grades sands, gravelly sands little or no fines.		4	17	13
Sandy gravel: Poorly-graded gravels, gravel-sand mixtures, little or no fines.		17	20	3
Sandy gravel with cobbles: Well-graded gravels, gravel-sand mixtures, little or no fines.		20	36	16
Silty sand: Silty sands, sand-silt mixtures.		36	37	1
Well-graded gravel: Well-graded gravels, gravel-sand mixtures, little or no fines.		37	40	3
Gravelly sand; Well-graded sands, gravelly sands, little or no fines.		40	50	10

8. WELL CONSTRUCTION
 Depth Drilled 79.6 Feet Depth Cased 79.6 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
7.1/2 Inches 0 Feet 79.6 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 80	0	79.6
End Cap—Locking cap				
7" Steel flush Mount				

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation .020
 From 7.5 feet to 79.6 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
2-64 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 64-71
 Gravel Packed: Yes No Silica Sand: #3
 From 71 feet to 79.6 feet

Date started 1/18/95, 19____
 Date completed 1/19/95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			
<i>Plugged by log 122461</i>			

9. WATER LEVEL
 Static water level NA feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed Jerry C. Johnson
 By driller performing actual drilling on site or contractor
 Date March 13, 1995