

Log No. **48506**  
 Permit No. \_\_\_\_\_  
 Basin **087**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22856

Consultant:

1. OWNER Broadbent & Associates, Inc. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1000 Bible Way, Suite 57 Allied Petroleum  
Reno, Nv. 89502 2500 E. 4th St. Reno, Nv.  
 2. LOCATION 1/4 087 1/4 Sec 7 T. 19N N/S R. 20 E Washoe County  
 PERMIT NO. M/O 702-A SP1 008-228-01 E. Reno area  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravelly sand and silt: Silty gravels, gravel-sand silt mixtures.		0	3	3
Clay: Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, lean clays.		3	4	1
Gravelly sand: Well-graded sands, gravelly sands, little or no fines.		4	19	15
Sandy Gravel with cobbles: Well-graded gravels, gravel-sand mixtures, little or no fines.		19	40	21
Boulder: Well-graded gravel:		40	44	4
Will-graded gravels, gravel-sand mixtures, little or no fines.		44	50	6
Well-graded gravel: Well-graded gravels, gravel-sand mixtures, little or no fines.		50	66	16
Sandy silt: Silty sands, gravelly sands, little or no fines.		66	75	9

(continued on)

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 80 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 7 1/2 Inches To 80 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		80 SCH	0	80
End Cap-Locking Cap				
7" Steel flush mount				

Perforations:  
 Type perforation Factory Sawn Slot  
 Size perforation .020  
 From 75 feet to 80 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3-64  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Bentonite Seal: 64-70  
 Gravel Packed:  Yes  No #3 Silica Sand  
 From 70 feet to 80 feet

9. WATER LEVEL  
 Static water level: NA feet below land surface  
 Artesian flow: NA G.P.M. NA P.S.I.  
 Water temperature: NA °F Quality: NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board: 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date March 13, 1995

Date started 1/19/95, 19\_\_\_\_  
 Date completed 1/20/95, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
no test			
<u>plugged by log</u>		<u>62</u>	<u>06</u>
			<u>122456</u>

