

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 126075

1. OWNER CHURCHILL CO. ROAD DEPT. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 330 N. BROADWAY ST. FALLON, NV. SAME  
 2. LOCATION SE 1/4 SW 1/4 Sec. 30 T. 19 N. R. 29 E CHURCHILL County  
 PERMIT NO. M/O 761 Issued by Water Resources Parcel No. 01-051-09 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  
 Deepen  Abandon  Other \_\_\_\_\_  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG MW-9

Material	Water Strata	From	To	Thickness
ASPHALTIC CONCRETE	-	0	6"	6"
LIGHT BROWN SILTY SAND	-	6"	2'	1 1/2'
DARK GRAY CLAYEY SAND	-	2'	5 1/2'	3 1/2'
LIGHT BROWN SILTY SAND	7'	5 1/2'	20'	14 1/2'

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>SC4.40</u>	<u>PVC</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.020"  
 From 5 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 4'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 4 feet to 20 feet

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature COLD °F Quality N/A

Date started 5/5 1994  
 Date completed 5/5 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDRESEN EXPLORATION DRILLING Contractor  
 Address 1635 BELFORD RD. Contractor  
RENO, NV. 89509  
 Nevada contractor's license number issued by the State Contractor's Board 0034525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6/13/94