

PROOF OF COMPLETION OF WORK

Log # 48523  
Basutt 10-75  
I

Permit No. 55497

STATE OF NEVADA

COUNTY OF WHITE PINE

} ss.

Comes now Doug Bailey, the Mine Manager  
Permittee or Agent

who after being first sworn, deposes and says that at least sixty thousand dollars (\$ 60,000)  
has been expended in work or improvements performed or made under the conditions provided in Permit No.  
55497, pertaining to the completion of said works, and at the expense of the permittee.

Said improvements consisted of drilled and cased well 10 inch diameter, and 626 feet  
If an underground source, state size and depth of well with casing and make and type of pump and motor.  
deep. A Berkely Submersible pump, model #682AH12, with a 60 hp Franklin motor  
was installed. A six (6) inch McCrometer totalizing Flowmeter, Model #M0306,  
serial #95 456 6 was installed, initial meter reading - 0 gallons.

The casing is slotted from 506 feet to 626 feet. The SWL is 539 feet.

said work being essential to the actual diversion of the water ~~applied for and in the~~ completion of the work required under  
said permit. Said work completed prior to January 31, 1995

Point of diversion located within the SE 1/4 NE 1/4 Sec. 35, T. 22 N., S. R. 57 E., M. D. B. & M.

WELL DRILLER unknown

Name and Address

WELL LOG FILED Yes   
No

Subscribed and sworn to before me this 2nd day of  
March, 1995

Theona Richie

Notary Public in and for the County of White Pine,

State of Nevada

My commission expires April 16, 1998.

Signed [Signature]  
Permittee or Agent  
Address P.O. Box 830  
Street No. or P.O. Box No.  
Ely, NV 89301  
City, State, Zip Code No.



(Ten dollar filing fee must accompany this proof)

SARGENT IRRIGATION COMPANY

Page 2 Log # 1003



CLIENT Alligator Ridge Prop LOCATION Baldmt mine JOB # \_\_\_\_\_

REPORT DATE 2-21-95 TIME ON SITE \_\_\_\_\_ OFF SITE \_\_\_\_\_ PAGE 1

WELL # P-1 CASING 10 <sup>10</sup> INCH DEPTH 626 FEET GRAVEL PACK YES NO

PUMP: LINE SHAFT  SUBMERSIBLE  DISCHARGE: \_\_\_\_\_

PUMP: SET PULL DEPTH 597 FEET COLUMN PIPE 3 INCH BOWL 57AH-7 INCH  
ENGINE 60 H.p. STAGES 14  
FUEL \_\_\_\_\_ GALLONS \_\_\_\_\_

STATIC WATER LEVEL 539.0 FEET BELOW GROUND LEVEL ARTESIAN FLOW \_\_\_\_\_ GPM  
WATER TEMP \_\_\_\_\_ COLD WARM HOT QUALITY \_\_\_\_\_ GOOD POOR CLOUDY ODOR

TYPE OF TEST PUMP: DEVELOPMENT \_\_\_\_\_ STEP \_\_\_\_\_ CONSTANT \_\_\_\_\_ RECOVERY \_\_\_\_\_

RPM	GPM	PUMPING LEVEL	HOURS	RPM	GPM	PUMPING LEVEL	HOURS
Pulled <u>4 1/2</u> ft of <u>4" x 2 1/2</u> ft							
<u>555</u> ft of <u>3" x 2 1/2</u> ft							
TOTAL <u>597</u> FT							
Berkeley Pump Ser # <u>2628795</u>							
Model <u>57AH-12</u>							
Impeller dia <u>3-25/32 x 4 1/4</u>							
<u>B-56875</u>							
<u>14 STAGE</u>							
(1) <u>3" CHECK VALVE TOP OF</u>							
<u>Pump</u>							
FRANKLIN Elec Motor							
Model <u>2366196015</u> , <u>60 H.P.</u>							
<u>PH 3</u> , <u>WTS 460</u> , <u>Rpm 2150</u>							
<u>HZ 60</u> , <u>AMP 580.5</u> , <u>KW 45</u>							
<u>S.F. 1.15</u> , <u>KVA code H/F</u>							
<u>S.F. MAX Amps 910</u>							
Elec. wire <u>F/AT 2/0 600V</u>							

TOTAL DEVELOPMENT HOURS \_\_\_\_\_  
 TOTAL STEP HOURS \_\_\_\_\_  
 TOTAL CONSTANT HOURS \_\_\_\_\_  
 TOTAL RECOVERY HOURS \_\_\_\_\_  
 TOTAL TEST HOURS \_\_\_\_\_

CREW	HRS	COMMENTS
<u>Rob</u>	<u>113 1/2</u>	
<u>Randy</u>	<u>113 1/2</u>	
<u>Row</u>	<u>113 1/2</u>	

APPROVAL: \_\_\_\_\_