

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 48529
 Permit No. 070
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32879

1. OWNER Gary Tompkins
 MAILING ADDRESS 9200 S. Beechcraft Winnemucca, NV 89445
 ADDRESS AT WELL LOCATION same #3

2. LOCATION NE 1/4 SE 1/4 Sec. 26 T. 35 N S R. 37 E Humboldt County
 PERMIT NO. 60012T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	20	20
Sand & Gravel		20	45	25
Sand & Clay		49	54	5
Sand & Gravel		54	58	4
Sand & Clay		58	66	8
Sand & Gravel		66	67	1
Sand & Clay		67	95	28
Sand/Clay/Gravel		95	108	13
Sand & Clay		108	120	12
Sand & Gravel		120	135	15
Pea Gravel		135	138	3
Sand/Gravel/Clay		138	143	5
Sand & Gravel		143	158	15
Clay		158	164	6
Sand & Gravel		164	195	31
Clay & Sand		195	200	5
Sand/Gravel/Clay		200	202	2
Clay		202	209	7
Sand & Gravel		224	227	3
Pea Gravel		227	235	8
Sand & Gravel		235	245	10
Sand/Gravel/Clay		245	250	5
Clay		250	253	3
Sand & Gravel		253	265	12
Sand/Gravel/Clay		265	267	2
Sand & Gravel		267	272	5
Sand/Gravel/clay		272	294	22
Brown Sand & Clay		294	304	10
Sand & Gravel		304	312	8

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation Mill slot/Roscoe Moss full flow
 Size perforation 1/8 x 2 1/2

From Blank +1 feet to 100 feet
 From DR Mill 100 feet to 120 feet
 From Roscoe Perf 120 feet to 160 feet
 From DR Mill 160 feet to 220 feet
 From Roscoe Pf 220 feet to 260 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started _____, 19____
 Date completed _____, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co Inc.
 Contractor

Address P O Box 590
 Contractor
 Winnemucca, NV 89446

Nevada contractor's license number 015234
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154

Signed _____
 By driller performing actual drilling on site or contractor

Date _____

