

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 48530
Permit No. _____
Basin. 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27758

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801
2. LOCATION SW 1/4 NE 1/4 Sec. 24 T. 36 N/S R. 49 E EUREKA County
PERMIT NO. 55139 N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN ROCK, CLAY			75	75
WHITE CLAY		75	95	20
BLACK ROCK, CLAY		95	180	75
BLACK ROCK, FRACT		180	260	80
BLACK ROCK, CLAY		260	305	45
BLACK ROCK, FRACT		305	570	265
BLACK ROCK, CLAY		570	610	40
BLACK ROCK		610	775	165
BLACK ROCK, CLAY		775	830	55
BLACK ROCK, HARD		830	1170	340
BLACK ROCK, WHITE CLAY		1170	1245	75
BLACK ROCK		1245	1270	25
BLACK ROCK, CLAY		1270	1335	65
BLACK ROCK, FRACT		1335	1375	40
BLACK ROCK, WHITE CLAY		1375	1395	20
BLACK ROCK		1395	1450	55
BLACK ROCK, WHITE CLAY		1450	1530	80
BLACK ROCK, FRACT CALSIT	X	1530	1610	80
BLACK LIMESTONE - FRACTURED		1610	2115	505

8. WELL CONSTRUCTION
Depth Drilled 2,115 Feet Depth Cased 2,115 Feet
HOLE DIAMETER (BIT SIZE)
From 40 Inches To 50 Feet
29 Inches 50 Feet 1,610 Feet
19 Inches 1,610 Feet 2,115 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
34 134.67 .375 0 50
20 78.60 .375 0 1,606
Perforations:
Type perforation LOUVERED
Size perforation 1/8"
From 20" 796 feet to 1,596 feet
From 16 1/2" 1,593 feet to 2,115 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 1,610 feet

Date started MARCH 1, 1995
Date completed MARCH 10, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
Static water level 1500 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature _____ °F Quality _____
10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number 0021976
issued by the State Contractor's Board
Nevada driller's license number 1716 issued by the Division of Water Resources, the on-site driller
Signed DAVID HAAS *David Haas*
By driller performing actual drilling on site or contractor
Date MAY 11, 1995