PZ93-18

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48531 & 48532
Permit No.
Basin 061

NOTICE OF INTENT NO. 24297

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ SE ¼ Sec. 19 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. M/O-441A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DISPLACED 16 LB/GAL CEMENT				
SLURRY FROM 740 FT TO SURFACE IN				
FIRST COMPLETION,				
AND FROM 455 FT TO SURFACE IN				
SECOND COMPLETION.				

MAY 18 AM 10:40 '95 STATE ENGINEER

Date started MAY 3, 19 95
Date completed MAY 3, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 740 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 3/4 Inches	0 Feet	40 Feet
6 1/4 Inches	40 Feet	800 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	+3	40
#1 1 1/4	2	SCH 40	+3	700
#2 1 1/4	2	SCH 40	+3	415

Perforations:
Type perforation SLOTTED
Size perforation 1/8"
From #1 700 feet to 740 feet
From #2 415 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From #1 690-740 feet to #2 405-465 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716
Signed DAVID HAAS (By driller performing actual drilling on site or contractor)
Date MAY 11, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627