WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48544
Permit No.
Basin 101

NOTICE OF INTENT NO. 28721

1. OWNER Avon Young
MAILING ADDRESS Fallon NV
ADDRESS AT WELL LOCATION 7780 Cury Rd Fallon NV 89406

2. LOCATION NE ¼ NW ¼ Sec. 2 T. 17 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 0631-2 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Sands | | 0 | 15 | 15 |
| Brown Clay | | 15 | 18 | 3 |
| Grey Sand | | 18 | 29 | 11 |
| Grey Clay | | 29 | 30 | 1 |
| Brown Sands | | 30 | 41 | 11 |

Date started 6-21, 1995
Date completed 6-22, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | | 1 hr |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 18 3/4 | 0 | 25 |
| 6 1/8 | 25 | 41 |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.8 | 18/8 | 0 | 41 |
| | | | | |

Perforations:
Type perforation Factory cut
Size perforation .080
From 34 feet to 39 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp (Contractor)
Address 335 N Broadway (Contractor)
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772-1
Signed Jesus Manzanarez (By driller performing actual drilling on site or contractor)
Date 6-22-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627