WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4854B
Permit No.
Basin 085

NOTICE OF INTENT NO. 32557

1. OWNER DAVID KOLIHA
MAILING ADDRESS 8905 Jedediah Smith Dr.
Sparks, NV 89436

ADDRESS AT WELL LOCATION 250 Quivera
Sparks, NV 89436

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 21N N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-310-13 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil w/volc. boulder		0	1	1
Boulders, gravel w/brown clay		1	6	5
Brown clay		6	49	43
Gray clay		49	92	43
Green clay		92	130	38
Brown clay		130	163	33
Brown volcanic rock		163	241	78
Gray volcanic rock		241	318	77
Black volcanic rock		318	341	23
Brown volcanic rock		341	349	8
Light brown volcanic rock w/brown clay streaks		349	412	63
Brown volcanic rock		412	449	37
Fracture/NO WATER		449	451	2
Brown volcanic rock		451	489	38
Black to brown volcanic rock		489	511	22
Fracture zone (app 2 GPM)	X	511	518	7
Black volcanic rock		518	530	12
Fracture rock	X	530	580	50
Brown & black volcanic rock		580	588	8

Date started 8-9-95, 19
Date completed 8-14-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6		

8. WELL CONSTRUCTION
Depth Drilled 588 Feet Depth Cased 588 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	588 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	588

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 583 feet to 563 feet
From 523 feet to 503 feet
From 443 feet to 423 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 588 feet

9. WATER LEVEL
Static water level 520 feet below land surface
Artesian flow G.P.M. 6 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 16, 1995

RECEIVED 95 AUG 21 AM 12:26 DIVISION OF WATER RESOURCES

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627