WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48564
Permit No.
Basin 048

NOTICE OF INTENT NO. 30004

1. OWNER Walt Lake
MAILING ADDRESS 1370 Sage Crest Dr #183
Elko, NV 89801

ADDRESS AT WELL LOCATION Spring Creek-
near Spring Creek Trap & Skeet

2. LOCATION NE ¼ SW ¼ Sec. 23 T 33 N N/S R 56 E Elko County
PERMIT NO. Issued by Water Resources | 79-001-07 Parcel No. | Ruby Mountain Estates Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	3	3
sand & gravel		3	15	12
clay		15	18	3
sand & gravel	x	18	150	132

RECEIVED 95 AUG 21 PM 12:28 STATE ENGINEER'S OFFICE

Date started July 26, 19 95
Date completed July 27, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
blow	55		2½

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 5/8 Inches	0 Feet	20 Feet
10 5/8 Inches	20 Feet	150 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	11	.188	+1.5	150

Perforations:
Type perforation mill slot
Size perforation 3/16 X 3" 6 row
From 125 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 8' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold°F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, Nevada 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-7-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627