

KINSLEE WELL

WHITE—DIVISION OF WATER RESOURCES  
CANARY—CLIENT'S COPY  
PINK—WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 48565  
Permit No.  
Basin. 045

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32149

1. OWNER John Sustacha ADDRESS AT WELL LOCATION Sustacha Dr.  
MAILING ADDRESS P. O. Box 28-1458 Lamolille, Nevada 89828 parcel #7  
Lamolille, Nevada 89828

2. LOCATION SE 1/4 SW 1/4 Sec 29 T 33N N/S R 58 E Elko County  
PERMIT NO. 107-080-AT  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	4	4
sandy clay & gravel		4	35	31
brown clay		35	45	10
sand-gravel-boulders XX		45	120	75

8. WELL CONSTRUCTION  
Depth Drilled 120 Feet Depth Cased 120 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10.5/8 Inches 0 Feet 120 Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6 5/8 11 188 +1 1/2 120  
Perforations:  
Type perforation mill slot  
Size perforation 3/16" X 3" 6 row  
From 100 feet to 120 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 120 feet

RECEIVED  
15 AUG 21 PM 12:26  
STATE ENGINEERS OFFICE

9. WATER LEVEL  
Static water level 40 feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature cold°F Quality good

7. WELL TEST DATA  
TEST METHOD:  Bailer  Pump  Air Lift  
G.P.M. Draw Down (Feet Below Static) Time (Hours)  
blow test 50 3

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Hackworth Drilling Inc Contractor  
Address P. O. Box 850 Contractor  
Elko, Nevada 89803  
Nevada contractor's license number issued by the State Contractor's Board 020582  
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1654  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 8-7-95