

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29559

1. OWNER ED AND CHERYL BLISS ADDRESS AT WELL LOCATION Right Hand Canyon Road
 MAILING ADDRESS 70 Columbia Ave Reno, NV 89510
Redwood City, CA 94063
 2. LOCATION NW 1/4 NE 1/4 Sec 29 T 22N N/S R. 22 E Washoe County
 PERMIT NO. 077-300-14 Palomino Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------------------|--------------|------|-----|------------|
| Top soil with volcanic gravels | | 0 | 3 | 3 |
| Red Clay with some gravels | | 3 | 23 | 20 |
| Brown clay | | 23 | 37 | 14 |
| Brown volcanic rock | | 37 | 63 | 26 |
| Brown clay with some gravels | | 63 | 115 | 52 |
| Brown volcanic rock | | 115 | 146 | 31 |
| Weathered granite | | 146 | 166 | 20 |
| Fracture | X | 166 | 171 | 5 |
| Weathered granite | | 171 | 209 | 38 |
| Fracture | X | 209 | 211 | 2 |
| Weathered Granite | | 211 | 225 | 14 |

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 225 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | | .188 | 0 | 225 |

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 160 feet to 180 feet
 From 200 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 225 feet

9. WATER LEVEL
 Static water level 66 feet below land surface
 Artesian flow _____ G.P.M. 17 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date August 18, 1995

Date started 8-16-95, 19____
 Date completed 8-17-95, 19____

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | | |
|---|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| 17 | | | |

RECEIVED
 05/10/21 11:12:20
 STATE ENGINEERS OFFICE