

WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 48568  
 Permit No. 087  
 Basin 087

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29219

1. OWNER Mike Fritz ADDRESS AT WELL LOCATION 14095 Torvinen  
 MAILING ADDRESS 2911 Chavez Reno, NV 89511  
Reno, NV 89502  
 2. LOCATION NW 1/4 NE 1/4 Sec. 30 T. 18N N/S R. 20 E Washoe County  
 PERMIT NO. 49-371-10 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand/clay/boulders		0	60	60
Granite/valcanics		60	160	100
Water stain gravel-granite		160	310	150
Brown clay w/rocks		310	380	70
Multi colored pea gravel w/ sands	xx	380	407	27

8. WELL CONSTRUCTION  
 Depth Drilled 407 Feet Depth Cased 407 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 407 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	.188	+1	407

Perforations: Factory  
 Type perforation 3/32 x 3 single row  
 Size perforation 387 feet to 407 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 407 feet

9. WATER LEVEL  
 Static water level 303 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MacKay Pump & Geothermal, Inc. Contractor  
 Address 1600 Mt. Rose Hwy. Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719  
 Signed P. Bunn  
 By driller performing actual drilling on site or contractor  
 Date 8-8-95

Date started 7-26 1995  
 Date completed 7-28 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	40	-	2

RECEIVED  
 AUG 21 PM 2:26  
 STATE ENGINEERS OFFICE