

MW 95-2  
 STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Log No. **48571**  
 Permit No. **1378**  
 Basin **1378**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **25435**

1. OWNER **Round Mountain Gold Corp.** ADDRESS AT WELL LOCATION **R.M.G.C. Minesite**  
 MAILING ADDRESS **P.O. Box 480**  
**Round Mountain, NV, 89045**

2. LOCATION **N.W. 1/4 S.W. 1/4 Sec. 29 T. 10 N. R. 44 E. Nye County**  
 PERMIT NO. **M/O 901**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Type I densely welded Tuff		0	165	
TRANSITION between Type I + Type II		165	250	
Type II poorly welded Tuff	?	250	435	
Granite		435	530	

8. WELL CONSTRUCTION  
 Depth Drilled **530** Feet Depth Cased **50** Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
**10 5/8** Inches **0** Feet **50** Feet  
**6 7/8** Inches **50** Feet **530** Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 7/8</b>	<b>12.81</b>	<b>.188</b>	<b>+1</b>	<b>50</b>
<b>2"</b>	<b>T&amp;C</b>		<b>+2</b>	<b>420</b>

Perforations:  
 Type perforation **NONE**  
 Size perforation  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **52'**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From feet to feet

9. WATER LEVEL  
 Static water level **98** feet below land surface  
 Artesian flow **20** G.P.M. P.S.I.  
 Water temperature **104** °F Quality **Poor**

Date started **March 14, 1995**  
 Date completed **March 16, 1995**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>20</b>		<b>4 hrs.</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Waytek Drilling Co.** Contractor  
 Address **2220 Stowe Dr** Contractor  
**Reno, NV, 89511**

Nevada contractor's license number issued by the State Contractor's Board **024521**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1442**

Signed **Les Waytek**  
 By driller performing actual drilling on site or contractor  
 Date **3-17-95**