Plugging

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48574
Permit No.
Basin 1037

NOTICE OF INTENT NO. 29427

1. OWNER Gardnerville Ranchos Improvement Dist
MAILING ADDRESS 931 Mica DR. Gardnerville NV 89410
ADDRESS AT WELL LOCATION Patrick DR. Gardnerville NV 89410

2. LOCATION SE ¼ SE ¼ Sec. 21 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. W-422 (Issued by Water Resources) Nona (Parcel No.) Gardnerville Ranchos (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☑ Other Test Hole

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lg ¼" Cobbles		0	2	20
Lg ¼ Gravels W/Imbedded Obsidian Sands		20	50	30
Imbeded Course Obsidian Sands W/clayballs		50	75	25
Course Gravels (Hard)		75	137	62
Dk Sands W/Light Brown Clay (Hard)		137	165	28
(Hard Smooth) Granite		165	240	75
Brown Smooth Clay in Hard Granite		240	300	60
From 165' to 300' No Change In Drilling formation (Hard Granite W/Some Clay) (No Drilling Breaks Where there Could be any Water)				
(Plugged Entire Hole)				

Date started 3-16, 1995
Date completed 3-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
DRY		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased None Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 3/4 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	N/A			

Perforations:
Type perforation N/A
Size perforation N/A
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 300' Hole plug
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level Dry feet below land surface
Artesian flow G.P.M. Dry P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 6561 Hwy 50 E #3 (Contractor)
Carson City NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-21-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627