WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48579
Permit No.
Basin 090

NOTICE OF INTENT NO. 24711

1. OWNER Mario Isola New Idaho Property Inc
MAILING ADDRESS 5270 Neil Road Suite 203 Reno NV
ADDRESS AT WELL LOCATION Whispering Pines 1820 Highway 50 Glenbrook NV

2. LOCATION NE ¼ SW ¼ Sec. 15 T. 14 N/S R. 18 E. Douglas County
PERMIT NO. Old M/O 602 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-4

Material	Water Strata	From	To	Thickness
Sand	24.5	0'	30'	30'

The well was found in good condition we removed the Christy Box and drilled out the casing. We then pressure grouted the hole from the bottom up using neat cement. We mixed the neat cement at a ratio of one sack of cement per 5 gallons of water

Date started 3-18, 1994
Date completed 3-18, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

N/A

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Sch. 40	PVC	0	30

Perforations:
Type perforation Factory Slot
Size perforation .020
From feet to feet
From 7.5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30 ~~3~~ ~~15~~
Placement Method: ☒ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6 feet to 30 feet

9. WATER LEVEL
Static water level 24.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1667
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627