WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48585
Permit No.
Basin 104

NOTICE OF INTENT NO 24707

1. OWNER Old Supreme Court Bldg
MAILING ADDRESS Carson City NV
ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ SE ¼ Sec. 17 T. 15 N/S R. 20 E. Carson County
PERMIT NO Old M10 059 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-2

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty Sand | No | 0 | 7' | 7' |
| Sand | No | 7 | 12 | 12 |
| Gravelly Sand | Yes | 19 | 23 | 4 |
| Sand | Yes | 23 | 25 | 2 |

The well was found in good condition. We removed the chrisky box and drilled out the casing. Then we pressure grouted the hole from the bottom up using a neat cement mix. The mix consisted of cement mixed with water at a rate of one sack of cement per 5 gallons of water.

Date started 4/22, 1994
Date completed 4/22, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | N/A | |

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 25 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | Sch. 40 | PVC | 0 | 25 |

Perforations:
Type perforation Factory slot
Size perforation .020
From feet to feet
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5 feet to 25 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1667
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627