WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48588
Permit No.
Basin 103

NOTICE OF INTENT NO. 3122

Consultant:
1. ~~OWNER~~ Klohn Leonoff Ltd.
MAILING ADDRESS 10200 Shellbridge Way
Richmond, B.C., Canada V6X2W7

Client:
ADDRESS AT WELL LOCATION Siskon Corporation
333 S. Carson Meadow Dr. Unit 44
Carson City, Nevada 89701

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 16N N/S R. 21 E. Storey County
PERMIT NO M/O-195 Well KLDH-2 (Issued by Water Resources) | Parcel No. | American Flat Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, some silt, some stone content, moderately dense, moderately stiff, medium dense, reddish brown		0	4	4
Volcanics, reddish brown, reddish brown silty clay matrix		4	15	11
Andesite, dark grey, medium plasticity, silty clay matrix		15	20	5
Andesite, light grey, silty, non-conesive matrix.		20	40	20

Date started September 28, 19 89
Date completed September 28, 19 89

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches		0 Feet	40 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		Sch 40	0	40
Locking Monuments				

Perforations:
Type perforation Factory Sawed Slot
Size perforation .020
From 35 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6'
Placement Method: ☐ Pumped ☒ Poured
Bentonita Seal 6-11
Gravel Packed: ☒ Yes ☐ No Lone Star #3
From 11 feet to 40 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 11, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627