

Log No. **48600**
 Permit No. **17**
 Basin **17**
 page **1** of **1** page
 NOTICE OF INTENT NO. **23386**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Consultant:

1- OWNER Pezonella & Associates ADDRESS AT WELL LOCATION Reson, Inc. 208 4th St. 4th & Lake Street Reno, Nevada
 MAILING ADDRESS 520 Edison Way Reno, NV 89502
 2. LOCATION NW 1/4 NW 11 T 19N N/S R. 19 E Washoe County Reno
 PERMIT NO. M/O 619 B MW#8 007-311-09 Issued by Water Resources Parcel No. Reno Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other TUBEX-190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt & Gravel		0	1	1
Brown Sandy Clay with gravels		1	11	10
Brown silty sand with clay fines		11	22 1/2	11 1/2
Dark brown-gray silty sand with gravels (rock content increased at 24 feet)		22 1/2	33	10 1/2
Changed to lighter brown color, rock content same		33	40	7

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 5/16 Inches To 40 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC	SCH 40		0	16
3/4" PVC	Sparger		0	38
And Locking Cap				

Perforations:
 Type perforation Factory Sawn slot
 Size perforation .020
 From 16 feet to 36 feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 0-10 1/2
 Placement Method: Pumped Poured
 Bentonite Seal 33-36'
 Gravel Packed: Yes No Pea Gravel
 From 10 1/2-36 feet to 36-40 feet

Date started 11-22-93, 19.....
 Date completed 11-23-93, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			

9. #3 Sand WATER LEVEL
 Static water level NA feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 908
 Signed [Signature] driller performing actual drilling on site or contractor
 Date March 30, 1995