

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 48602
 Permit No. 48602
 Basin 089

NOTICE OF INTENT NO. 26485

Consultant:

1. OWNER Agra Earth & Environmental, Inc ADDRESS AT WELL LOCATION
 MAILING ADDRESS 737 East Glendale Ave. Project "C"
Sparks, NV 89431 4th Street
 2. LOCATION NW 1/4 SW 1/4 Sec. 11 T. 19N N/S R. 19 E Washoe County
 PERMIT NO. M/O 720A Sp-1 007-293-18 Downtown Reno
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other Tubeax

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Backfill- Decomposed Granite		0	6	6
Clayey silty Sands with gravels and boulders, sand are medium to coarse grained, loose, unconsolidated, dark gray		6	25 1/2	19 1/2
Sandy Clay, with some gravel, highly plastic, light to medium brown		25 1/2	27.10	2 1/2

8. WELL CONSTRUCTION
 Depth Drilled 27.10 Feet Depth Cased 27.10 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 1/2 Inches To 0 Feet 27.10 Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	+2	27.10

 End Cap & Locking Cap
 Sparge
 Perforations:
 Type perforation Factory Sawn Slot
 Size perforation .020
 From 21 feet to 27.10 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 0-19 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Bentonite Seal: 19-22
 Gravel Packed: Yes No #8 Sand
 From 22 feet to 27.10 feet

Date started 5-2-94, 19.....
 Date completed 5-2-94, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed Gary A. Hedman
 By driller performing actual drilling on site or contractor
 Date April 5, 1995