WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

FOR OFFICE USE ONLY
Log No. 48603
Permit No.
Basin 007

NOTICE OF INTENT NO. 26485

Consultant:

1. ~~OWNER~~ Agra Earth & environmental, Inc
MAILING ADDRESS 737 East Glendale Ave.
Sparks, NV 89431

Client:
ADDRESS AT WELL LOCATION
Project "C"
4th Street

2. LOCATION NW ¼ SW ¼ Sec. 11 T 19N N/S R 19 E Washoe County

PERMIT NO. M/O 720 A SP-2 (Issued by Water Resources) | 007-293-18 (Parcel No.) | Downtown Reno (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Backfill- Decomposed Granite.		0	6	6
Clayey silty sands with gravels and boulders, sands medium to coarse, loose, unconsolidated, dark gray.		6	24½	18½
Sandy clay, with some gravel, highly plastic, light to medium brown.		24½	26.20	1½

Date started 5-3-94, 19
Date completed 5-3-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

8. WELL CONSTRUCTION
Depth Drilled 26.20 Feet Depth Cased 26.20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7½ Inches		0 Feet	26.20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	+2	26.20
End Cap & Locking Sparge				

Perforations:
Type perforation Factory sawed slot
Size perforation .020
From 20½ feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-18
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 18-20
Gravel Packed: ☒ Yes ☐ No #8 Sand
From 20 feet to 26.20 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 5, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627