WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

FOR OFFICE USE ONLY
Log No. 48604
Permit No.
Basin 087

NOTICE OF INTENT NO. 26485

Consultant:
1. ~~OWNER~~ Agra Earth & Environmental, Inc.
MAILING ADDRESS 737 East Glendale Ave.
Sparks, NV 89431

Client:
ADDRESS AT WELL LOCATION
Project "C"
4th Street

2. LOCATION NW ¼ SW ¼ Sec. 11 T 19N N/S R 19 E Washoe County
PERMIT NO. M/O 720A MW1 (Issued by Water Resources) 007-293-18 (Parcel No.) Down Town Reno (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☒ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Backfill- Decomposed Granite		0	6½	6½
Clayey Silty Sands, with gravels and boulders, medium to coarse grained sand, loose unconsolidated dark gray		6½	24	17½
Sandy Clay, highly plastic, light to medium brown		24	24½	½

Date started 5-2-94, 19
Date completed 5-2-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

8. WELL CONSTRUCTION
Depth Drilled 24.50 Feet Depth Cased 24.50 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7¼ Inches	0 Feet	24.50 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	+2	24½
End Cap & Locking				

Perforations:
Type perforation Factory Sawed Slot
Size perforation .020
From 4½ feet to 24½ feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 0-2'
Gravel Packed: ☒ Yes ☐ No #8 Sand
From 2 feet to 24½ feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date April 5, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627