WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

DIVISION USE ONLY
Log No. 48606
Permit No.
Basin 077

NOTICE OF INTENT NO. 24708

1. OWNER Ray Herring
MAILING ADDRESS 1008 East 4th Street Reno NV
ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NW ¼ Sec. 12 T. 19 ☒S R. 19 E. Washoe County
PERMIT NO. Old M/O 608 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other Auger

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thickness
Sand & Gravel Backfill	No	0	14'	14'
Sandy Gravel	No	14'	16'	2'
Boulder	No	16'	18'	2'
Sand	No	18'	26'	8'
Sandy Gravel	No	26'	30'	4'
Sand	No	30'	34'	4'
Clayey Sand	No	34'	35'	1'

The well was in good condition we removed the charity box and drilled out the casing. We pressure grouted from the bottom of the hole up using neat cement. We mixed the neat cement at a ratio of 1 sack of cement per 5 gallons of water

Date started 3-17, 19 94
Date completed 3-17, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		N/A

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
5	0	35

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Sch. 40	PVC	0	35

Perforations:
Type perforation Factory slot
Size perforation .020 Inch
From ___ feet to ___ feet
From 15 feet to 35 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 35
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 35 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1667
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627