WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48623
Permit No.
Basin

NOTICE OF INTENT NO. 17096

1. OWNER Paula Holmes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2990 E. Kellogg

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 21 S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 44-61 3-03 (Parcel No.) Conestoga Est. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3'
Caliche		3	5	2'
Clay		5	23	18'
Caliche		23	26	3'
Clay		26	38	12'
Caliche		38	41	3'
Clay		41	54	13'
Caliche	WB	54	58	4'
Clay		58	65	7'
Caliche	W.B.	65	67	2'
Clay		67	78	11'
Caliche	WB	78	83	5'
Clay		83	91	8'
Caliche	W.B.	91	94	3'
Clay		94	106	12'
Caliche	WB.	106	108	2'
Clay		108	116	8'
Caliche	WB.	116	119	3'
Clay		119	125	6'
Caliche	WB	125	128	3'
Clay		128	136	8'
Caliche	WB.	136	139	3'
Clay		139	140	1'

DCNR/DWR Received OCT 9 1995 LAS VEGAS OFFICE

Date started 9-25, 1995
Date completed 9-29, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12 ¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAWCUT
Size perforation 1/8" X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~1462~~ 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 10/2/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627