WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48631
Permit No.
Basin 162

NOTICE OF INTENT NO. 14450

1. OWNER Stella A Williams
MAILING ADDRESS HCR 66 Box 53206 Pahrump NEV 89041
ADDRESS AT WELL LOCATION Gally ST LOT 10

2. LOCATION SE ¼ NE ¼ Sec. 28 T. 19S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 29-89-210 (Parcel No.) BELL VISTA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brn Clay		1	26	25
Hard Brn Clay		26	39	13
Brn Clay		39	46	7
Hard Brn Clay		46	54	8
Brn Clay		54	63	9
Hard Brn Caliche		63	67	4
Brn Clay	WB	67	79	12
Hard Brn Clay		79	82	3
Clay Gravel Rocks	WB	82	94	12
Brn Clay Gravel	WB	94	111	17
Hard Brn Clay		111	128	17
Brn Clay	WB	128	137	9
Hard Brn Clay		137	158	21
Sandy Brn Clay	WB	158	162	4
Brn Clay	WB	162	170	8
Hard Brn Clay		170	200	30

DCNR/DWR Received OCT 10 1995 LAS VEGAS OFFICE

Date started SEPT 18, 1995
Date completed SEPT 22, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	36 hr

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12½ Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	188	0	200

Perforations:
Type perforation Torch Cut
Size perforation 44 X 6"
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling (Contractor)
Address Box 265 Pahrump NEV 89041 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625
Signed Ron Naillon (By driller performing actual drilling on site or contractor)
Date OCT 2 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627