WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No: 48644
Permit No. 24689
Basin 162
NOTICE OF INTENT NO. 17075

1. OWNER Tom Liouvas
MAILING ADDRESS
ADDRESS AT WELL LOCATION Homestead Rd.

2. LOCATION SE ¼ SE ¼ Sec. 12 T. 21S N/S R. 53 E. Nye County
PERMIT NO. 24689 (Issued by Water Resources) 44-531-05 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	14	10
Calichie		14	16	2
Clay		16	22	6
Calichie		22	24	2
Clay		24	29	5
Calichie		29	33	4
Clay		33	45	12
Calichie		45	47	2
Clay		47	54	7
Calichie	WB	54	58	4
Clay		58	69	11
Calichie	WB	69	105	36
Clay		105	108	3
Calichie	WB	108	114	6
Clay		114	120	6
Calichie	WB	120	129	9
Clay		129	132	3
Calichie	WB	132	136	4
Clay		134	147	13
Calichie	WB	147	149	2
Clay		149	166	17
Calichie	WB	166	171	5
Clay		171	177	6
Calichie	WB	177	180	3
Clay		180	200	20

Date started August 30, 19 95
Date completed ~~August~~ September 1, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR Received OCT 6 1995 LAS VEGAS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	200

Perforations:
Type perforation Factory Saw cut
Size perforation 1/8" x 1 3/4"
From feet to feet
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~1526~~ 1642
Signed Thomas Dann (By driller performing actual drilling on site or contractor)
Date 9/25/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627