

OFFICE USE ONLY
 Log No. 48647
 Permit No. _____
 Basin. 163

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17062

1. OWNER William Hintz ADDRESS AT WELL LOCATION SILVER AV. + JR. EWING TRAIL SANDY VALLEY NV.
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SW 1/4 SE 1/4 Sec. 9 T. 25 N/S R. 57 E CLARK County
 PERMIT NO. 590-390-083 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	15	15
CLAY + GRAVEL		15	30	15
ROCK + GRAVEL		30	45	15
CLAY + GRAVEL		45	55	10
CEMENTED SAND + GRAVEL		55	58	3
SAND + GRAVEL	W.B	58	65	7
CLAY + GRAVEL		65	70	5
SAND + GRAVEL	W.B	70	120	50

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 2 INCH BY 3 INCH
 From 120 feet to 100 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 120 feet to 50 feet

9. WATER LEVEL
 Static water level 5.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
 Address HCR 78 Box 80358 Pahrump NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1573
 Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 9-19-95

Date started 9-7, 1995
 Date completed 9-18, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

