WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48656
Permit No.
Basin 162

NOTICE OF INTENT NO. 17064

1. OWNER John Hardman
MAILING ADDRESS
ADDRESS AT WELL LOCATION ~~Beneth~~ 4721 W. Victoria

2. LOCATION SW ¼ SE ¼ Sec. 23 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 128-823-09 (Parcel No.) Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Caliche		2	6	4
Clay		6	11	5
Calichie		11	13	2
Clay		13	19	6
Calichie		19	22	3
Clay		22	38	16
Calichie		38	43	5
Clay		43	53	10
Calichie	WB	53	57	4
Clay		57	65	11
Calichie	WB	65	71	6
Clay		71	89	18
Calichie	WB	89	93	4
Clay		93	101	8
Calichie	WB	101	106	5
Clay		106	114	8
Calichie	WB	114	117	3
Clay		117	125	8
Calichie	WB	125	128	3
Clay		128	137	9
Calichie	WB	137	140	3

DCNR/DWR Received OCT 6 1995 LAS VEGAS OFFICE

Date Started August 22, 19 95
Date completed August 24, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 36880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dw (By driller performing actual drilling on site or contractor)
Date 9/9/95

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627