

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26336

1. OWNER Jerry Edgemon ADDRESS AT WELL LOCATION 4112 Weaver Rd
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec 18 T 18 N/S R 29 E Churchill County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand	✓	0	17	17
Brown Clay		17	24	7
Brown Sand	✓	24	38	14
Black Sand	✓	38	67	29
Black Silt	✓	67	74	7
Black Silty Clay		74	87	13
Dark Sand	✓	87	107	20
Grey Sand & Gravel	✓	107	115	8
Brown Silty Clay		115	127	12
Brown Fine Sand	✓	127	153	26

8. WELL CONSTRUCTION
 Depth Drilled 153 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches _____ Feet 50 Feet
6 Inches 50 Feet 153 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.9</u>	<u>.184</u>	<u>71</u>	<u>145</u>

Perforations:
 Type perforation Machine slot
 Size perforation .080
 From _____ feet to _____ feet
 From 137 feet to 143 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 11-6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welco Contractor
 Address Box 888 Contractor
Fallon
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 172
 Signed W. Edgemon
 By driller performing actual drilling on site or contractor
 Date June 25-94

Date started June 14, 1994
 Date completed June 14, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>3</u>