WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48677
Permit No.
Basin 212

NOTICE OF INTENT NO. 16274

1. OWNER Lionel Sawyer & Collins
MAILING ADDRESS 300 South 4th St. Las Vegas NV 89101
ADDRESS AT WELL LOCATION SE Corner of Charleston & Lindell.

2. LOCATION NW ¼ NE ¼ Sec. 01 T. 21 N/S R. 60 E. Clark County
PERMIT NO. M0-2394 (Issued by Water Resources) 162-01-501-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-10
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand		0	2	2
Caliche		2	3	1
Silty Sand		3	4	1
Caliche		4	6.5	2.5
Silty Sand		6.5	7.5	1
Caliche		7.5	9	1.5
Silty Fine Sand		9	13.5	4.5
Caliche		13.5	15	1.5
Fine Sand		15	28	13
Gravelly Sand		28	30	2
Silty Sand		30	35	5
Sand		35	40	5
Silty Sand		40	45	5
Sandy Clay		45	65	20

DCNR/DWR Received OCT 2 1995 OFFICE

Date started Aug 14, 1995
Date completed Aug 14, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	65 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	65

Perforations:
Type perforation Factory Slot
Size perforation 0.020
From 35 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1'/1-8' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 65 feet

9. WATER LEVEL
Static water level 53.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High
Contractor
Address 4670 So. Polaris Ave
Contractor
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board:
Nevada driller's license number issued by the Division of Water Resources, the on site driller. M1869
Signed Tom High
By driller performing actual drilling on site or contractor
Date 9-26-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627