WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48694
Permit No.
Basin 0924

NOTICE OF INTENT NO. 37254

1. OWNER David McIlroy
MAILING ADDRESS 2100 Richter Drive
Reno, Nevada 89509

ADDRESS AT WELL LOCATION Wagon Ho Lane
Reno, Nevada 89506

2. LOCATION SW ¼ SE ¼ Sec 25 T 21 N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-370-05 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 1 | 1 |
| Brown clay | | 1 | 16 | 15 |
| Soft Zone (soft sandy clay) | | 16 | 21 | 5 |
| Brown clay | | 21 | 61 | 40 |
| Brown sand | | 61 | 63 | 2 |
| Brown clay | | 63 | 99 | 36 |
| Blue clay | | 99 | 106 | 7 |
| Gray clay | | 106 | 111 | 5 |
| Gray Med to Coarse sand | | 111 | 126 | 15 |
| Gray Clay | | 126 | 135 | 9 |

Date started 6/8/95, 19
Date completed 6/9/95, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | |

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 100 Feet |
| 8 5/8 Inches | | 100 Feet | 135 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 0 | 135 |

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 108 feet to 128 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100 Pentelon w/ Ingro
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 135 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 13, 1995

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627