REPORT NO. 95.34

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 48695
PERMIT NO.
BASIN 083

NOTICE OF INTENT NO. 28529

OWNER Phillip Orth
MAILING ADDRESS 1800 Kietzke Ln #2 Reno, Nv 89502

ADDRESS OF WELL 21640 Sarazac
Reno, Nv 89511

2. WELL LOCATION NW 1/4 SE 1/4 SEC. 32 T 18N R 21 E Storey COUNTY

PERMIT NO. ____ PARCEL NO 03-052-12 SUBDIVISION NAME Virginia City Highlands

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Overburden		0	20	20
Red & brown rock & clay		20	40	20
Green & brown rock & clay		40	60	20
Green & gray rock, some clay		60	80	20
Green, gray, black & white rock with		80		
some clay		80	100	20
Green & white rock, some brown		100	120	20
Green & white rock, some black		120	160	40
Green & white rock		160	180	20
Black rock with some white		180	200	20
Black & white rock, some green		200	220	20
Black, white, green & brown rock		220	250	30
Black rock, some white		250	260	10
Green rock with some brown rock		260	278	18

Notes :

Date Started 6/12/95 Date Completed 6/15/95

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	20+		3

8. WELL CONSTRUCTION

Depth Drilled 278 Depth Cased 278

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 51 Feet
8 1/2 Inches 51 Feet 278 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	278

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 238 Feet to 258 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 51'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 51 Feet to 278 Feet

9. WATER LEVEL

Static Water Level 10 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated 6/15/95