WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

SEE Log #38063
48716

FOR USE ONLY
Log No.
Permit No.
Basin
NOTICE OF INTENT NO. 2457

1. OWNER Rodney Fair
MAILING ADDRESS 1646 Nevada Way
Boulder City, NV. 89005
ADDRESS AT WELL LOCATION 2570 Tuscarora
Ave Reno NV

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. R194 mo 493 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The well was found to be in good condition. There was no water. I removed the christy box, perforated the bottom plug of the casing. Then, using a mix of water and portland type I-II cement mixed at a ratio of 6 gallons of water per sack of cement, I treminied the grout into the well using about 35 gallons of grout.				

Date started 8-26, 1993
Date completed 8-26, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		NA

8. WELL CONSTRUCTION
Depth Drilled 54 Feet Depth Cased 54 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
5	Inches	0	Feet	54	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch. 40	0	54

Perforations:
Type perforation Factory Slot
Size perforation .020 Inch
From feet to feet
From 44 feet to 54 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40 feet Bentonite Plug 40-42
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 42 feet to 54 feet

9. WATER LEVEL
Static water level None feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anderson Exploration Drilling (Contractor)
Address 1635 Milford Rd Reno NV (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources the on-site driller M1667
Signed (By driller performing actual drilling on site or contractor)
Date 6/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627