

Log No. 48717
 Permit No. 182
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27275

consultant:

1. ~~OWNER~~ Steffen Robertson & Kirsten ADDRESS AT WELL LOCATION: Western Energetix/ International Place
 MAILING ADDRESS 1755 Plumb Lane, Suite 241 755 International Place, Sparks NV
Reno, Nv 89502

2. LOCATION NW 1/4 NE 1/4 Sec 6 T 19 N/S R 20 E Washoe County
 PERMIT NO. M/O-902 MW #4 032-302-21 Sparks Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other ODEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	5"	5"
Dark Brown silty fine to medium Sands- moist		5"	1.5'	1'
Dark brown gravelly Sands- slightly moist-size of gravels range from 1/3" -1"		1.5	6.5	5
Brown medium Sands- Gravel mixture- slightly moist-size of gravel range from 1/3"-1"		6.5	9	2.5
Yellowish brown fine to medium sand with minor fine Gravel		9	13	4
Brown coarse Sand (with minor medium sand) and Gravels-size of gravels range from 1/3"-1". Moist from 13-18', very moist at 19' & wet below 23'.		13	25	12
Brown silty fine to medium Sands with Gravels- gravel size ranges from 1/2"-1". Saturated.		25	30	5
Brown clayey silty fine to medium SAND with minor Gravels.		30	39	9

8. WELL CONSTRUCTION
 Depth Drilled 39 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 5/16 Inches To 0 Feet 39 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	39

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation .020
 From 4 feet to 39 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 0-2' Cement Grout
 Placement Method: Pumped Concrete Grout
 Bentonite Seal: Poured 4'
 Gravel Packed: Yes No Silica Sand: 4'-39'
 From feet to feet

9. WATER LEVEL
 Static water level 22.7 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nv 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date March 27, 1995

Date started 3/8/95, 19
 Date completed 3/8/95, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			
NO TEST			