

Log No. 48118
Permit No. I
Basin 087
Page 1 of
NOTICE OF INTENT NO. 22856

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Consultant:

1. OWNER Broadbent & Associates, Inc. ADDRESS AT WELL LOCATION Allied Petroleum
MAILING ADDRESS 1000 Bible Way, Suite 57 2500 E. 4th St. Reno, NV
Reno, Nv 89502
2. LOCATION 1/4 087 1/4 Sec. 7 T. 19N N/S R. 20 E Washoe County
PERMIT NO. M/O 702-A RW-11B 008-228-01 E. Reno Area
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty gravel: Silty gravels, gravel-sand-silt mixtures.		0	2	2
Gravelly sand: Poorly grade sands, gravelly sands, little or no fines		2	11	9
Sandy gravel: Poorly-graded gravels, gravel-sand mixtures, little or no fines.		11	20	9
Well-graded gravel: Well-graded gravels, gravel-sand mixtures, little or no fines.		20	50	30
Well-graded gravel: Well-graded gravel, gravel-sand mixtures, little or no fines.		50	74	24
Sandy Clay: Inorganic clays of low to medium plasticity, gravelly clays, silty clays, lean clays.		74	75	1
Silty Gravel: Silty gravels, gravel-sand-silt mixtures		75	85	10

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet
HOLE DIAMETER (BIT SIZE)
From To
9 5/16 Inches 0 Feet 85 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 80	0	85
End Cap- Locking Cap				
8" Steel Flush mount				

Perforations:
Type perforation factory sawed slot
Size perforation .020
From 44 feet to 85 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 3-38 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Bentonite Seal: 38-42
Gravel Packed: Yes No #3 Silica Sand:
From 42 feet to 85 feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor
Address P.o. Box 12370 Contractor
Reno, Nv 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [Signature] by driller performing actual drilling on site or contractor
Date March 13, 1995

Date started 2/7/95, 19.....
Date completed 2/8/95, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			
<i>Plugged by log 2245</i>			