WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

FOR DWR USE
Log No. 49719
Permit No.
Basin 187

page 1 of 1 page
NOTICE OF INTENT NO. 22856

Consultant:
~~1. OWNER~~ Broadbent & Associates, Inc.
MAILING ADDRESS 1000 Bible Way, Suite 57
Reno, Nv 89502

ADDRESS AT WELL LOCATION
Allied Petroleum
2500 E 4th St. Reno Nevada

2. LOCATION ¼ 087 ¼ Sec. 7 T 19N N/S R 20 E Washoe County

PERMIT NO. M/O 702-A V-1 (Issued by Water Resources) | 008-228-01 (Parcel No.) | E. Reno Area (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey fine sand: Inorganic silts and very fine sands, rock flour, silty or clayey fine sands, or clayey silts weth slight plasticity.		0	5	5
Well-graded sand: Well-graded sands, gravelly sands, little or no fines.		5	13	8
Gravel and sand: Poorly graded gravels, gravel-sand mixtures, little or no fines.		13	21	8
Cobbles and gravel: Well-graded gravels, gravel-sand mixtures, little or no fines.		21	60	39

Date started 1/31/95, 19
Date completed 2/2/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	60 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 80	0	60
End Cap-Locking Cap				
8" Steel flush mount.				

Perforations:
Type perforation Factory sawed slot
Size perforation .020
From 38 feet to 58 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4-35
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 35-37
Gravel Packed: ☒ Yes ☐ No #3 Silica Sand:
From 37 feet to 60 feet

9. WATER LEVEL
Static water level NA feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 16, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627