WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 40725
Permit No.
Basin 081

consultant:

~~1. OWNER~~ ERM EnvioClean-West

MAILING ADDRESS 1777 Botellho Drive, Suite 210
Walnut Creek, CA 94596

ADDRESS AT WELL LOCATION 1235 Glendale Avenue
Sparks, NV 89431

NOTICE OF INTENT NO. 26487

2. LOCATION SW ¼ NE ¼ Sec. 8 T 19 N/S R 20 E Washoe County

PERMIT NO. M/O 589 MW#2 (Issued by Water Resources) | 034-091-05 (Parcel No.) | Sparks (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Monitor Well Abandonment				
Static Water level in well 10.12'.				
Total depth of well 23.0'.				
Equipment used:				
T660 Schramm Drill with 2 man crew.				
Tremie pipe.				
Materials used:				
7 sacks Portland Cement type II, total.				
1 sack Bentonite.				
Method:				
Glue threaded adapter to existing casing.				
Set tremie pipe to bottom of casing.				
Pump neat cement from bottom to surface(3 sacks)				
Pull tremie, fill casing& attach from cement pump directly to casing.				
pump cement @ 80-100 PSI squeezing cement through perforations into the surrounding formation. (4 Sacks). When pressure increases, discontinue pumping.				
Remove trafic covers, cut casing below grade & patch cement.				

Date started 4/25/94, 19
Date completed 4/25/94, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL

Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed (By driller performing actual drilling on site or contractor)

Date March 31, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627