

Log No. **48727**
 Permit No. **087**
 Basin **I**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26487

Consultant:

1. OWNER: ERM Enviro Clean-West ADDRESS AT WELL LOCATION: _____
 MAILING ADDRESS: 1777 Botelho Drive, Suite 210 1235 Glendale Avenue
Walnut Creek, CA 94596 Sparks, NV 89431
 2. LOCATION: SW 1/4 NE 1/4 Sec. 8 T. 19 N/S R. 20 E Washoe County
 PERMIT NO. M/O 589 MW#4 034-091-05 Sparks
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE: Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE: Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--|--------------|------|----|-----------|
| Monitor Well Abandonment | | | | |
| Static water level in well | | | | 9.95' |
| Total depth of well | | | | 24.8' |
| Equipment used: T660 Schramm Drill with 2 man crew. Tremie pipe. | | | | |
| Materials used: 10 sacks Portland cement Type II, total. 1 sack Bentonite. | | | | |
| Method: Glue threaded adapter to existing casing. Set tremie pipe to bottom of casing. Pump neat cement from bottom to surface (3 sacks) Pull tremie, fill casing & attach from cement pump directly to casing. Pump cement @80-100 PSI squeezing cement through perforations into the surrounding formation (7 Sacks). When pressure increases, discontinue pumping Remove traffic cover, cut casing below grade & patch. | | | | |

8. WELL CONSTRUCTION

Depth Drilled: _____ Feet Depth Cased: _____ Feet

HOLE DIAMETER (BIT SIZE)

| From | | To | |
|--------|------|------|------|
| Inches | Feet | Feet | Feet |
| Inches | Feet | Feet | Feet |
| Inches | Feet | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| | | | | |

Perforations:

Type perforation: _____
 Size perforation: _____

| From | feet to | feet |
|------|---------|------|
| From | feet to | feet |

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started: 4-25-94, 19____
 Date completed: 4-25-94, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |

9. WATER LEVEL

Static water level: _____ feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature: _____ °F Quality: _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Wayne Drilling Inc. Contractor
 Address: P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board: 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908
 Signed: [Signature] by driller performing actual drilling on site or contractor
 Date: March 31, 1995