WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48733
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 27744

1. OWNER Woodward Prop.-Robert H. Brown
MAILING ADDRESS 12241 Pioneer Way
Fallon, NV 89406

ADDRESS AT WELL LOCATION Approx 6 miles SW of Fallon - 12241 Pioneer Way, Fallon, NV

2. LOCATION SW ¼ SW ¼ Sec. 29 T 19 (N) S R 27 E Churchill County

PERMIT NO. ~~11146~~ 30625 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Clay		10	45	35
Gray Clay		45	93	47
Brown Clay		93	107	14
Sand & Gravel w/some cobbles		107	160	53
Coarse sand w/traces of clay		160	180	20
Sand & Gravel		180	198	18
Compacted sand		198	270	72
Coarse sand		270	275	5
Sandy Clay		275	318	43
Hard Sand		318	330	12
Sandy Clay		330	355	25
Clay		355	380	25

Date started March 1, 19 95
Date completed March 4, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1200	120	

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 362 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
36 Inches		0 Feet	50 Feet
24 Inches		50 Feet	380 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	Culvert	.126	0	50
12 3/4	33.38	.250	+2	100

Perforations:
Type perforation Louvered 1/8 slot-H.D. screen 1/8
Size perforation Triple Mill Slot 1/8
From S. Louvered 100 feet to 120 feet
From Screen 120 feet to 160 feet
From S. Louvered 160 feet to 210 feet
From Triple Mill 210 feet to 362 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 362 feet

9. WATER LEVEL
Static water level 81' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. (Contractor)
Address P O Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed C. C. Eyler (By driller performing actual drilling on site or contractor)
Date 3-29-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627