WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48740
Permit No.
Basin

12DADD-2

NOTICE OF INTENT NO. 24418

Consultant:

1. OWNER Groundwater Rescources Consult. Inc. ADDRESS AT WELL LOCATION 25555 Whiskey Springs Rd
MAILING ADDRESS 1735 East Fort Lowell Rd #4 Rocketdyne Former Field Lab
Tucson, AZ 85719 Reno, NV

2. LOCATION NE ¼ SE ¼ Sec 12 T. 22N N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 077-110-01 (Parcel No.) Spanish Springs Unit 1 12.2.1.5 (Subdivision Name)

3. WORK PERFORMED 18364
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Static water level in well 32 feet.				
Total depth of well 170 feet.				
Equipment used:				
T660 Schramm Drill with 2 man crew.				
Mills Knife air operated perforator.				
168 feet x 1½" dia. Tremie pipe.				
Materials used:				
42 sacks Portland Cement Type II, total.				
1 sack Bentonite				
Method:				
Casing could not be pulled.				
Casing perforated between 155 feet and 0. *				
Evidence of existing seal NONE.				
Pumped cement through tremie pipe with 37 sacks				
Fluid level to surface YES.				
5 sacks cement make up to surface.				
Cut casing below grade and finish.				
NOTE: * Slot size 5/16 x 2½, 4 holes around				
on 2 feet intervauls.				
Location:				
1400 feet in a direction N 2° W from SE corner				
of S 12.				

Date started 4-10-94, 19
Date completed 4-11-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date June 29, 1994

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627