

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 48779

Permit No. _____

Basin. 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. N/A

1. OWNER Winnemucca Farms ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P O Box 130
Winnemucca, NV 89446

2. LOCATION SW 1/4 SE 1/4 Sec 1 T 35 N 37 E Humboldt County _____
 PERMIT NO. MO-923 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Clay		8	20	12
Sand w/clay		20	43	23
Silty Clay		43	55	12
Sand w/some clay		55	86	31
This well, #1-A, was off-set approx. 15 ft. west of well #1				
Well #1-A was drilled due to the screened section of well #1 being below static water level				
Stainless centralizers Top & Bottom				

8. WELL CONSTRUCTION
 Depth Drilled 83 Feet Depth Cased 81 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 83 Feet
6 1/2 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2	PVC	Sch. 80	+1	50
2 1/2	PVC	Sch. 80	80	81

Perforations:
 Type perforation Sch. 80 PVC Screen
 Size perforation .020
 From 50 feet to 80 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout
 Poured Concrete Grout
 Depth of Seal 48

Gravel Packed: Yes No 6 x 12 mesh
 From 48 feet to 83 feet

Date started April 23 1995
 Date completed April 23 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>til Clear</u>	<u>1/2</u>		<u>3 hrs</u>

9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Norm °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co Inc. Contractor
 Address P O Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed C. E. Gaylor
 By driller performing actual drilling on site or contractor
 Date 5-10-95