Well #2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48780
Permit No.
Basin 07

NOTICE OF INTENT NO. 27933

1. OWNER Winnemucca Farms
MAILING ADDRESS P O Box 130
ADDRESS AT WELL LOCATION 1 mile west of Winnemucca

2. LOCATION SE/NE/4 SW 1/4 Sec. 1 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. M0-923 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	20	20
Silty Clay		20	40	20
Sand & Gravel		40	42	2
Silty Clay		42	55	13
Sand & Gravel		55	78	23
Silty Clay w/sand		78	85	7

Letter attached on material & construction

stainless centralizers top & bottom

PLUGGED BY
NOI # 64373

40.934563°N
117.768010°W
NAD 27 (To)

MAY 16 A10:51 95 STATE ENGINEERS OFFICE

Date started April 21, 19 95
Date completed April 21, 19 95

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Til Clear	1		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/2 Inches		0 Feet	88 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2"	PVC	Sch 80	+1	50
2 1/2"	PVC	Sch 80	80	85

Perforations:
Type perforation Schd 80 PVC Screen
Size perforation .020
From 50 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No 6x12 mesh
From 50 feet to 85 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Norm °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co Inc (Contractor)
Address P O Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed C. C. Eppler (By driller performing actual drilling on site or contractor)
Date 5-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627