PW-11

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48793
Permit No.
Basin 031

NOTICE OF INTENT NO. 6398

1. OWNER AMAX GOLD INC
MAILING ADDRESS 600 SOD HOUSE ROAD
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
AMAX SLEEPER MINE

2. LOCATION SE ¼ SW ¼ Sec 16 T 40 (N)S R 35 E HUMBOLDT County
PERMIT NO. 49763 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP 195 FEET OF ORIGINAL WELL WAS MINED				
AWAY BY THE OPEN PIT MINING OPERATION.				
THE REMAINING 125 FEET OF WELL WAS				
ABANDONED WITH A 75 VISCOSITY - 9 LB/GAL				
BENTONITE SLURRY DISPLACED INTO THE BOTTOM				
68 FEET OF WELL, AND A 57 FOOT 16 LB/GAL				
CEMENT SLURRY PLACED ON TOP OF THE				
BENTONITE				

Date started MARCH 8, 19 95
Date completed MARCH 8, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 1/2 Inches		0 Feet	320 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.38	.250	+1	50
			125	165
			195	203
			233	265

Perforations:
Type perforation MILL SLOT
Size perforation 1/8" X 3"
From 50 feet to 125 feet
From 165 feet to 195 feet
From 203 feet to 233 feet
From 265 feet to 305 feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 320 feet

9. WATER LEVEL
Static water level NONE feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed JOHN VIERGUTZ John Viergutz
(By driller performing actual drilling on site or contractor)
Date MARCH 22, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627