WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY.
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48799
Permit No.
Basin 207

NOTICE OF INTENT NO. 22964

1. OWNER Boyd & Rhonda Badder
MAILING ADDRESS Po Box 83 Lund NV 89317
ADDRESS AT WELL LOCATION 161 M. St Lund NV

2. LOCATION NW ¼ NE ¼ Sec. 33 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 06-017-02 (Parcel No.) Lund Townsite Survey (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	16"	
gravel Lime Stone		16"	9'	
clay		9	20	
gravel		20	21	water
clay		21	30	
gravel		30	32	water
clay		32	55	
gravel		55	56	water
clay		56	67	
gravel		67	68	water
clay		68	74	
gravel		74	75	water
clay		75	86	
gravel		86	87	water
clay		87	97	
gravel		97	98	water
clay		98	110	
gravel		110	112	water
clay		112	115	

'95 APR 17 P12:24
STATE ENGINEER

Date started Feb 16, 1995
Date completed March 17, 1995

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	42'	1 hr

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	115 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.4	.188	-1	115

Perforations:
Type perforation mill
Size perforation 1/8 x 2.5" x crow
From 8 feet to feet
From 73 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 115 feet

9. WATER LEVEL
Static water level 10.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Nathan R Maynard (Contractor)
Address P.O. Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022864
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Owen Maynard
By driller performing actual drilling on site or contractor
Date April 11-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627